

HYDROTRON HWF SERIES

Water Filter Dust Collectors



Wet Dust Collectors

Current Technology

Water Filter: The Hydrotron Wet Dust Collector Systems purify air by a combination of centrifugal force and the violent mixing of water and contaminated air. As the air stream passes the fixed baffles, particulate is separated by a heavy, turbulent curtain of water created by high velocity air. The centrifugal force caused by the rapid changes in airflow direction forces the dust particles to penetrate the water droplets and become entrapped. Contaminated water is then removed from the airstream by special mist filters. Dust, as sludge, settles to the bottom and the water is reused.

Automatic Fill System: Water make up is controlled by a pressure sensor system that is unaffected by debris in the water. The system also includes an electrical solenoid valve, isolation valve, and a manual fill/high-water sensor for reliable water control.



Stainless Steel Unit
With Sludge Conveyor

1-800-289-0189

Specifically Designed for Volatile Dust

Safety

Safe collection of aluminum, titanium, and other potentially hazardous dust, as well as heavy sparking applications, meeting or exceeding OSHA and NFPA regulations for dust removal inside the building.*

Energy Savings

Recirculation of clean, tempered air.

Configured to Meet the Need

The Hydrotron Series includes collectors ranging from 500 CFM to 9000 CFM, meeting a broad spectrum of industrial needs, whether single process or larger, multi-point operations. Optional drag-type sludge conveyors are available for heavy dust applications.

*NFPA guidelines for processing and finishing of aluminum, for example, prohibit the use of dry type dust collectors within the building. In addition, NFPA 65 specifies that collectors should be cleaned at least once a day. Explosion vents may be required and there are special requirements for ductwork. If the air is returned into the building it should have a HEPA type safety filter with an alarm function. Fabric and paper media filter units and electrostatic precipitators may not be used. The preferred collector is a liquid, wet type.

FILTER 1

CUSTOM SPECIALISTS FOR INDUSTRIAL NEEDS